



The mentioned product complies with the mentioned test requirement

Intertek LSS Scheme Tick Mark Certificate

18LHK0191-01

In accordance with the Tick Mark Rules and Certification System 5, as defined in ISO / IEC 17067:2013, we certify that the product(s)

Smoke and Carbon Monoxide Alarms

is in conformity with the following standard(s):
EN14604:2005+AC:2008, EN50291-1:2010+A1:2012

Report Number(s):
103281722LHD-011, 171114047GZU-001

Sprue Safety Products Ltd

Vanguard Centre, Sir William Lyons Road, Coventry, CV4 7EZ, United Kingdom

and is authorised to use the Intertek Tick Mark for the LSS Scheme on the above mentioned product(s)

This certificate is valid until:
13-Nov-2022

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee, and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

Limitations:	Certification Body: ITCL LSS Reference: LSS 0886 Issued Date: 13-Nov-2018
---------------------	--

Signed on behalf of Intertek, located at Leatherhead, United Kingdom



Certification Officer

Nick Jones





Intertek LSS Scheme Tick Mark Certificate

18LHK0191-01

The mentioned product
complies with the
mentioned test
requirement

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No. 1

Brand and Model	Description	Factory Code
FireAngel SCB10-xx	Smoke and Carbon Monoxide Alarm	SITERWCN.01
AngelEye SCB10-AE-xx	Smoke and Carbon Monoxide Alarm	SITERWCN.01

Note:

1. 'Model' refers to the packing code.
2. '-xx' denotes country, language and trade variants. Please refer to Annex No. 3 for approved options.

ANNEX No. 2

Batteries:

The FireAngel SCB10-xx and AngelEye SCB10-AE-xx Smoke and Carbon Monoxide Alarms contain 1 x built-in (non-replaceable) 3V lithium-ion battery, Type EVE CR17450; 10-year battery life.

CO Sensor Type:

Electrochemical

Conditions of use:

Suitable for indoor applications only

General notes:

The FireAngel SCB10-xx and AngelEye SCB10-AE-xx Smoke and Carbon Monoxide Alarms:

- are Type B alarms; this is in accordance with EN 50291-1:2010+A1:2012.
- have not been approved for installation into leisure accommodation vehicles (LAVs).



Intertek LSS Scheme Tick Mark Certificate

18LHK0191-01

The mentioned product
complies with the
mentioned test
requirement

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No. 3

Country, language and trade variants:

No suffix	United Kingdom
-AT	Austria
-AUS	Australia
-BE	Belgium
-BNL	Dual Language Belgium and Netherlands
-CEU	Central Europe
-DE	Germany
-DK	Denmark
-EEU	Eastern Europe
-ES	Spain
-EU	Generic European Variant
-FI	Finland
-FR	France
-HU	Hungary
-INT	International
-IT	Italy
-NCC	National Caravan Council
-NEU	Northern Europe
-NL	Netherlands
-NO	Norway
-PL	Poland
-Q	B&Q
-R	Retail
-SC	Scandinavia
-SE	Sweden
-SEU	Southern Europe
-T	Trade

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorised to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.